

**CERTIFICATE OF ANALYSIS**

Product Name:R32

Batch No.: 20240202-V1505A -1

Standard: AHRI700-2019

Sample Date:2nd Feb,2024

Inspect Date:2nd Feb,2024

## Inspect Result:

Items	Index		Results
	First grade		
Appearance	Colorless&no turbid		Colorless&no turbid
Smell	No strange stench		No strange stench
Purity (% by Weight) $\geq$	99.9		99.98
Water (ppm by weight) $\leq$	0.001		0.00078
Acidity (by weight as HCl) $\leq$	0.0001		0
Evaporation residue (by weight) $\leq$	0.01		0.0006
Non-absorbable gases (by volume in vapour phase) $\leq$	1.5		0.32
CL	PASS		PASS
Conclusion :	Excellent Grade		
Remark:			

Sample: Geng Xuejiao

Analyze:Geng Xuejiao

Review: Tao Lianxiu

Signed By \_\_\_\_\_

